



EVALUATION REPORT

FLORIDA BUILDING CODE, 6TH EDITION (2017)

Manufacturer: TRI-BUILT Materials Group *Issued July 2, 2018*
 9050 Louisiana Street
 Merrillville, IN 46410
 (800) 516-1485
www.tribuiltmaterialsgroup.com

Manufacturing Location: Tuscaloosa, AL

Quality Assurance: UL LLC (QUA9625)

SCOPE

Category: Roofing
Subcategory: Underlayments
Code Sections: 1504.3.1, 1507.1.1, 1523.1.1
Properties: Physical properties

REFERENCES

<u>Entity</u>	<u>Report No.</u>	<u>Standard</u>	<u>Year</u>
PRI Construction Materials Technologies (TST5878)	MSA-044-02-01	ASTM D 1970	2015a
PRI Construction Materials Technologies (TST5878)	MSA-047-02-01	ASTM D 1970	2015a

PRODUCT DESCRIPTION

Ice and Rain Stopper Ice and Rain Stopper is an ASTM D 1970 self-adhesive underlayment constructed from SBS modified asphalt, a fiberglass mat reinforcement and surfaced with granules. The product is supplied in 2-sq. rolls with nominal dimensions of 3-ft x 66.8-ft and has a nominal thickness of 50 mils.



PRODUCT APPLICATION

Min. Roof Slope: 2:12 or in accordance in with the FBC

Application: *All underlayments shall be installed in accordance with the FBC. In the HVHZ, the underlayment shall be installed in accordance with Section 1518.3.*

Deck substrates shall be clean, dry, and free from any irregularities and debris. All fasteners in the deck shall be checked for protrusion and corrected prior to underlayment application. Prior to beginning installation, the underlayment shall be unrolled and allowed to relax for a minimum of 3-5 minutes.

The underlayment shall be installed with the release backer removed and pressed firmly into place to ensure complete contact with the deck. The underlayment shall be installed with the roll length parallel to the eave, starting at the eave, and with minimum 3" side laps and minimum 6" end laps staggered min. 6-ft. from preceding course.

It is permissible to back nail the underlayment 12-inches on-center as needed (nails shall be installed perpendicular to deck with the nail heads flush to the top surface of the underlayment).

Min. Application Temperature: 40°F; *Contact the manufacturer when installing at temperatures below the minimum application temperature.*


Allowable Roof Coverings: Ice and Rain Stopper is permitted to be used as prescribed in FBC Section 1507.1.1 for mechanically attached roofing coverings.

GENERAL LIMITATIONS

- 1) Fire Classification is not within the scope of this evaluation.
- 2) Installation of the evaluated product shall comply with this report, the FBC, and the manufacturer's published application instructions. Where discrepancies exist between these sources, the more restrictive and FBC compliant installation detail shall prevail.
- 3) The roof deck shall be constructed of closely fitted plywood sheathing for new or existing construction.
- 4) The space under the deck area shall be properly ventilated in accordance with the FBC requirements.
- 5) All side lap seams shall be installed to shed water from the deck.
- 6) The underlayment may be used as described in other current FBC product approval documents.
- 7) The underlayment shall not be left exposed for longer than 30 days.
- 8) Design wind load pressures shall be determined for components and cladding in accordance with FBC 1609.
- 9) The roof deck shall be designed by others in accordance with FBC requirements to resist the design wind load pressures for components and cladding.
- 10) *Maximum Design Pressures* for a given underlayment shall meet or exceed the design wind loads determined for the roof assembly.
- 11) All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest, P.E. have demonstrated compliance with the Florida Building Code, 6th Edition (2017) as evidenced in the referenced documents submitted by the named manufacturer.



Zachary R. Priest, P.E.
Florida Registration No. 74021
Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT